

City of Anna Maria

PROGRESS SUMMARY

To: Bidders

From: City of Anna Maria

Date: February 28, 2020

Re: RFP-ITB No. 20-001

Addendum #4 – City Pier Restaurant and Bait Shop Lease

Addendum #5:

ADDITIONAL WRITTEN QUESTIONS

- 1. Can you provide the construction drawings for the project? AVAILABLE AT CITY HALL
- 2. Would it be possible to add a roof top deck to the structure? NOT AT THIS TIME
- 3. Is a grease trap/interceptor in place? Where is the location/Planned location? YES, ON SHORE
- 4. Is there gas service to the restaurant? If not has that been explored? LP GAS IN PLACE
- 5. The HVAC roof top unit is in place for the bait shop. Will HVAC be provided for the restaurant space? NEGOTIABLE
- 6. How large (in amperage) is the electrical service? 277 / 480-volt 3 phase 300 amp
- 7. How large is the boat dock? How many boats could it service at one time? NEGOTIABLE BUT MINIMUM OF 4 25' BOATS
- 8. Would it be possible to relocate the bait shop to the base of the pier allowing for a bar in its place? NEGOTIABLE
- 9. Where would the dumpster be located? ON SHORE IN FENCED AND GATED LOCATION
- 10. Will the pier have safety railing? ON THE ENTRY PORTION TO MEAN LOW TIDES
- 11. Where will benches be located on the pier? YES, how will it impact outdoor seating? UP TO TENANT AND CITY. NEGOTIABLE